

Pre-design sheet for an exergy optimised building design							
IEA ECBCS Annex 37							
Steady state calculations for heating case							
Version 2.3							
Object: The ZUB Office Building, IEA Annex 37 Demoproject							
1. Project data, boundary conditions							
1							
2	Volume (inside) [m ³]	V =	6882,35				
3	Net floor area [m ²]	A _N =	2202,35				
4	Indoor air temperature [°C]	θ _i =	21				
5	Exterior air temperature [°C]	θ _e =	0	= θ _{ref} Reference temperature			
2. Heat losses							
2.1 Transmission losses Φ_T [W]							
8	Building part	Symbols	Area A _i [m ²]	Thermal transmittance U _i [W/(m ² K)]	U _i * A _i [W/K]	Temperature-correction-factor F _{xi} [-]	U _i * A _i * F _{xi} [W/K]
9	Exterior wall	EW 1	430,36	0,13	55,95	1	55,95
10		EW 2	4,02	0,85	3,42	1	3,42
11		EW 3	277,71	0,27	74,98	0,5	37,49
12		EW 4	5,55	0,17	0,94	1	0,94
13	Window	W 1	482,35	0,80	385,88	1	385,88
14		W 2	64,10	0,80	51,28	1	51,28
15		W 3	104,62	0,90	94,16	1	94,16
16		W 4	12,78	1,20	15,34	1	15,34
17	Door	D 1	8,09	0,80	6,47	1	6,47
18	Roof	R 1	368,56	0,16	58,97	1	58,97
19		R 2	81,83	0,17	13,91	1	13,91
20		R 3				1	
21	Upper story floor	R 4				0,8	
22		R 5				0,8	
23	Wall to roof rooms	RW 1				0,8	
24		RW 2				0,8	
25	Walls and floors to unheated rooms	uhW 1				0,5	
26		uhW 2				0,5	
27	Floors to ground. Areas of unheated cellar to ground	G 1	396,07	0,26	102,98	0,6	61,79
28		G 2	86,09	0,20	17,22	0,6	10,33
29		G 3	12,06	0,20	2,41	0,6	1,45
30		G 4				0,6	
31		G 5				0,6	
32	Σ A _i = A =		2334,19	Specific transmission heat loss		Σ U _i * A _i * F _{xi} =	
33	Transmission heat losses [W]		Φ _T = Σ (U _i * A _i * F _{xi}) * (θ _i - θ _e)		Φ _T =		16.744,77
34	Φ _T =		797,37	* 21,00			
2.2 Ventilation heat losses Φ_V [W]							
35	Air exchange rate [ach/h]	n _d =	0,6				
36	Heat exchanger efficiency [-]	η _V =	0,8				
37	Ventilation heat losses [W]	Φ _V = (cp * ρ * V * n _d * (1-η _V)) * (θ _i - θ _e)				Φ _V =	
38	Φ _V =		276,67	* 21,00		5.810,08	
3. Heat gains							
3.1 Solar heat gains Φ_S [W]							
39							
40	Window frame fraction [-]	F _f =	0,3				
41	Orientation	Solar radiation I _{s,j} [W/m ²]		Window area A _{w,j} [m ²]	Total transmittance g _j [-]	I _{s,j} * (1-F _f) * 0,9 * 0,9 * A _{w,j} * g _j ⁽¹⁾ [W]	
42	south-east to south-west	20		435,03	0,42	2.071,96	
43				12,78	0,58	84,06	
44	north-west to north-east	20		31,26	0,42	148,89	
45							
46	other directions	50		81,90	0,42	975,18	
47							
48	Dormer window with slope < 30°	5					
49	Solar heat gains:		Φ _S = Σ (I _{s,j} * (1-F _f) * A _{w,j} * g _j)		Φ _S =		3.280,09
3.2 Internal Heat Gains Φ_I [W]							
50							
51	Number of occupants [-]:	n _o =	12,50				Φ _{i,o} =
52	Internal gains of occupants [W]:	Φ _{i,o} = n _o * Φ _{i,o} ⁽¹⁾		Φ _{i,o} =		1.000,00	
53	Spec. internal gains of equipment	Φ _{i,e} =	1,36				Φ _{i,e} =
54	Internal gains of equipment [W]:	Φ _{i,e} = Φ _{i,e} ⁽¹⁾ * A _N		Φ _{i,e} =		3.000,00	
55	Φ _{i,e} =		1,36	* 2.202,35			
4. Other uses							
56	Spec. lighting power [W/m ²]:	ρ _l =	2				P _l =
57	Lighting power [W]:	P _l = ρ _l * A _N		= Φ _{l,i}		4.404,70	
58	Spec. ventilation power [Wh/m ³]:	p _v =	0,54				P _v =
59	Ventilation power [W]:	P _v = p _v * V * n _d		P _v =		2.229,88	
59	P _v =		0,54	* 6.882,35		* 0,60	